



**THE CITY OF MARIETTA  
MARIETTA, GEORGIA  
November 12, 2014**

**Addendum # 2  
For**

**REPLACEMENT OF AN AIR COOLED WATER CHILLER AT THE BLW  
ADMINISTRATIVE OFFICES– RFB-15-36414**

**All prospective proposers are hereby advised to make the changes to the Bid documents in their possession as shown and/or described in the attached information:**

**Change, replace, add or delete the following in the above referenced bid:**

**UPDATE # 1 *Answers are Italicized.***

**Question# 1: Are the existing controls just sending Start/stop to chiller?**

***Answer: This is correct***

Please sign the Addendum below and include with your bid.

Signature: \_\_\_\_\_

Name: \_\_\_\_\_

Firm: \_\_\_\_\_

Date: \_\_\_\_\_

**Jameison A. Henderson  
Purchasing Agent II  
City of Marietta/BLW  
Purchasing Department  
Office: 770-794-5699  
JHenderson@mariettaga.gov**